




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Arbor Assisted Living	Provider Number 2663
Address 3500 9TH ST,	Approval Status Approved
City, State, Zip Bremerton, WA 98312	Facility Type Residential Care

On 03/31/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Jordan Gearheart Maint. Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Arbor Assisted Living	Provider Number	2663
Address	3500 9TH ST ,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98312	Facility Type	Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 COVID - 19 Pandemic (ALFs)

Memorandum of record:
Due to the state of emergency declaration of the COVID-19 pandemic event, DSHS revoked the request per RCW 18.20.130, of the Washington State Fire Marshal Office (SFMFO) to conduct renewal licensing inspections of licensed Assisted Living Facilities (ALFs) except those specifically requested by DSHS from April 1, 2020 to July 31, 2021. A 2021 renewal inspection request was not received for this facility.

2 Frequency

Frequency. Employees shall receive training in the contents of the emergency plans and their duties as part of new employee orientation and at least annually thereafter. Records shall be kept and made available to the fire code official upon request..

(IFC 406.2 2021 WAC 51-54A)

Findings during the inspection were:

Fire drills shall be conducted once per shift per quarter and documentation shall be provided for a whole year.

3 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Findings during the inspection were:

Facility failed to provide documentation of annual inspection of all fire-resistance-rated construction.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Arbor Assisted Living	Provider Number	2663
Address	3500 9TH ST ,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98312	Facility Type	Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the inspection were:

Facility failed to provide the following documentation for the automatic sprinkler system;

- Three year dry system full flow trip test.
- Annual forward flow test for the backflow.
- Fire department connection hydrostatic test.

Sprinkler report from 2-12-24 states water motor gong failed, deficiencies shall be corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Arbor Assisted Living
Address 3500 9TH ST ,
City, State, Zip Bremerton, WA 98312

Provider Number 2663
Approval Status Disapproved
Facility Type Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

5 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.

2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:

2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.

2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.

2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.

2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.

2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.

3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Findings during the inspection were:

Facility failed to maintain the following portable fire extinguishers;

- First floor laundry, extinguisher not mounted.
- Extinguisher over 5 feet high outside of 1st floor laundry.
- Extinguisher over 5 feet high outside of elevator room.

6 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during the inspection were:

Facility failed to provide monthly inspection of single station smoke alarms.

Smoke alarm report from 2-12-24 states smoke detector on second floor is damaged, deficiencies shall be corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Arbor Assisted Living
Address 3500 9TH ST,
City, State, Zip Bremerton, WA 98312

Provider Number 2663
Approval Status Disapproved
Facility Type Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

(IFC 915.6 2021 WAC)

Findings during the inspection were:

Facility failed to provide documentation showing testing and maintenance of carbon monoxide alarms.

8 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

Findings during the inspection were:

Facility failed to provide monthly 30 second inspection of exits and emergency lights.

9 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2021)

Findings during the inspection were:

Facility failed to provide annual 90 minute power test of all exit signs and emergency lights.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Arbor Assisted Living	Provider Number	2663
Address	3500 9TH ST ,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98312	Facility Type	Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

10 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:

1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.
2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.
3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.
4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.

Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing.

(IFC 5303.5.3 2021)

Findings during the inspection were:

Facility failed to maintain oxygen tanks in oxygen room, multiple oxygen tanks not secured.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Arbor Assisted Living	Provider Number	2663
Address	3500 9TH ST,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98312	Facility Type	Residential Care

On 02/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 03/20/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Jordan Gearheart Maint. Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

This document was prepared by Residential Care Services for the Locator website.