Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Valley Senior Living	***Provider Number***	2679
Address	8400 207th ,	***Approval Status***	Approved
City, State, Zip	Arlington, WA 98223	***Facility Type***	Residential Care

On 06/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Aaron Tipke Maint Dir
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cascade Valley Senior Living	***Provider Number***	2679
Address	8400 207th ,	***Approval Status***	Disapproved
City, State, Zip	Arlington, WA	***Facility Type***	Residential Care

On 03/04/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	1. As per documents provided the sprinkler system testing completed on 10/6/2025 had deficiencies noted that have not been corrected. a. Dry system coupling at the dry riser is leaking b. No evidence that the 15 year dry sprinkler heads have been tested. 2. Mixed standard response and quick response sprinkler heads were found in dining room. A wall was removed that joined two spaces.

Next inspection scheduled on or after: 04/03/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Aaron Tipke Maint Dir

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____