



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name Wellspring Residence

Provider Number 2685

Address 1215 S TOWER AVE ,

Approval Status Disapproved

City, State, Zip Centralia, WA 98531

Facility Type Residential Care

On 10/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Hold-Open Devices and Closers

Hold-open devices and automatic door closers, where provided, shall be maintained. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position.

(IFC 705.2.3 2021)

Room 113 and room 108 failed to close and latch

2 Operational Inspection and Testing

Emergency power systems, including all appurtenant components, shall be inspected and tested under load in accordance with NFPA 110 and NFPA 111.

Exception: Where the emergency power system is used for standby power or peak load shaving, such use shall be recorded and shall be allowed to be substituted for scheduled testing of the generator set, provided that appropriate records are maintained.

(IFC 1203.5 2021)


Facility failed to provide the following reports

Weekly inspection and monthly testing

Next inspection scheduled on or after: 11/04/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sierra Jones Med Tech
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2502 112 ST E
Tacoma WA 984455104
(509) 406-7209


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wellspring Residence	Provider Number	2685
Address	1215 S TOWER AVE ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA 98531	Facility Type	Residential Care

On 07/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Corrected
--	-----------

2 Hold-Open Devices and Closers

Hold-open devices and automatic door closers, where provided, shall be maintained. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position. (IFC 705.2.3 2021)	Door found wedged open for storage room Room 113 and room 108 failed to close and latch
--	--

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected
--	-----------

4 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Corrected
--	-----------

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wellspring Residence	Provider Number	2685
Address	1215 S TOWER AVE ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA 98531	Facility Type	Residential Care

On 07/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

5 Operational Inspection and Testing

Emergency power systems, including all appurtenant components, shall be inspected and tested under load in accordance with NFPA 110 and NFPA 111. Exception: Where the emergency power system is used for standby power or peak load shaving, such use shall be recorded and shall be allowed to be substituted for scheduled testing of the generator set, provided that appropriate records are maintained. (IFC 1203.5 2021)	Facility failed to provide the following reports Weekly inspection and monthly testing
---	---

6 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode. (WAC 212-12-044)	Corrected
---	-----------

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wellspring Residence	Provider Number	2685
Address	1215 S TOWER AVE ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA 98531	Facility Type	Residential Care

On 07/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 08/28/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sierra Jones Med Tech
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wellspring Residence	Provider Number	2685
Address	1215 S TOWER AVE ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA 98531	Facility Type	Residential Care

On 06/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Fire doors throughout found with pexi glass on bottom eighth of door
--	--

2 Hold-Open Devices and Closers

Hold-open devices and automatic door closers, where provided, shall be maintained. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position. (IFC 705.2.3 2021)	Door found wedged open for storage room Room 113 and room 108 failed to close and latch
--	--

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Facility failed to provide the following reports Quarterly fire sprinkler inspection report first quarter third quarter and fourth quarter
--	---

4 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Facility failed to provide the following reports Semi annual fire alarm system inspection
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Wellspring Residence

Provider Number 2685

Address 1215 S TOWER AVE ,

Approval Status Disapproved

City, State, Zip Centralia, WA 98531

Facility Type Residential Care

On 06/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

5 Operational Inspection and Testing

Emergency power systems, including all appurtenant components, shall be inspected and tested under load in accordance with NFPA 110 and NFPA 111.

Exception: Where the emergency power system is used for standby power or peak load shaving, such use shall be recorded and shall be allowed to be substituted for scheduled testing of the generator set, provided that appropriate records are maintained.

(IFC 1203.5 2021)

Facility failed to provide the following reports

Weekly inspection and monthly testing

6 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.

(WAC 212-12-044)

Facility failed to conduct fire drills once per shift per quarter with alarm activation during day shift and swing shift.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Wellspring Residence	Provider Number	2685
Address	1215 S TOWER AVE ,	Approval Status	Disapproved
City, State, Zip	Centralia, WA 98531	Facility Type	Residential Care

On 06/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 07/17/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

 Med Tech
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature

This document was prepared by Residential Care Services for the Locator website.