Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Van Mall Retirement	***Provider Number***	2702
Address	7808 51ST ST ,	***Approval Status***	Approved
City, State, Zip	Vancouver, WA 98662	***Facility Type***	Residential Care

On 06/25/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 228331 Here's a complaint of Fire Alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes. No	On 06/13/2026 at approximately 2030 a fire alarm activated in the building. The fire department responded to the fire alarm activation, however, they were unable to diagnose the origin/reason for the alarm activation. No fire was found, no sprinkler activation occurred. Staff responded to the fire alarm as required. When the fire alarm was going off a resident fell and was transported to the hospital for further evaluation as a result a fall.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Lisa Cianni

Signature

Lisa Cianni Executive Director

Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Nicholas D. Wolden

Signature

Initials of Authorized Facility Representative:_____

This document was prepared by Residential Care Services for the Locator website.