Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cherrywood Care	***Provider Number***	2571
Address	100 DALKE ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99208	***Facility Type***	Residential Care

On 09/18/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 240188 Here's a complaint of Fire Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? smoldering cigarette in trash can 2. If the sprinklers were activated? NO 3. If there was an evacuation / how many were evacuated? NONE 4. If there were injuries / how many? NONE 5. Did the fire department respond? YES	On September 18, 2026 a representative from the State Fire Marshals Office conducted a complaint inspection at Cherrywood Care located at 100 E Dalke Ave, Spokane WA to investigate complaint ref # 240188. I interviewed the Administrator and maintenance director. The incident was in regards to a resident who had a smoldering cigarette in their trash can in their room. The trash started to burn and produced smoke. The smoke detector in the resident room activated the fire alarm system. Staff responded and extinguished the fire according to the facility procedures. The fire department responded to the alarm and cleared the alarm. There were no evacuations or injuries. No violations cited.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Alejandra Pardomo Manera, Executive Director.
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara R. McMullen
Signature

Initials of Authorized Facility Representative: APM

This document was prepared by Residential Care Services for the Locator website.