Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sunnyside Care	**Provider Number**	2754
Address	907 IDA BELLE ST ,	**Approval Status**	Approved
City, State, Zip	Sunnyside, WA 989449062	**Facility Type**	Residential Care

On 06/10/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Admin Complaint	
COMPLAINT # 224713, 226587 Here's a complaint of Fire alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On May 10, 2026 an inspection was completed for complaint #224713 for Sunnyside Care Assisted Living located at 907 Ida Belle Street in Sunnyside, Washington. This inspection is in response to complaint for a water line break in the dining room hallway. The facility stated that the sprinkler line leak occurred on 5/16/26 when a vendor installing security cameras punctured the sprinkler line. The facility went into fire watch at 1300 on 5/16/26. The facility went off fire watch when the fire alarm and sprinkler line were repaired. No violations were observed and the above was discussed with facility staff.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Maribel Rojas, Executive Assistant
Print Name and Title

Deputy State Fire Marshal Kimberly Bloor
PO Box 42600
Olympia WA 985042600
(360) 596-3922

Kimberly Bloor
Signature

Digitally signed by Kimberly Bloor
Date: 2026.06.15 09:34:08 -07'00'

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.