Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sunnyside Care	***Provider Number***	2754
Address	907 IDA BELLE ST ,	***Approval Status***	Approved
City, State, Zip	Sunnyside, WA 989449062	***Facility Type***	Residential Care

On 08/12/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 235858 Here's a complaint of Water shut off Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On August 12, 2026, an inspection was completed for complaint #235858 at Sunnyside Care Assisted Living at 907 Ida Belle Street in Sunnyside, Washington. This inspection is in response to complaint for a water leak and utility failure. The facility stated that staff observed a water leak outside of Room 127 on the utility water pipe on August 9, 2026 at approximately 1100 hours. The facility was unable to obtain a repair on the water line on Sunday, but it was repaired on Monday, August 10, 2026 at approximately 1600 hours. During the water outage, staff handed out water bottles from their emergency supply per their emergency policies. Upon inspection of where the leak occurred, there was some water damage on the ceiling tiles, but were dry and placed back in position. There was no fire, no fire and life safety systems activated, and no staff or residents were injured, relocated, or evacuated. The fire alarm system showed normal status, and the fire department did not respond during this utility failure. No fire watch was required, although the facility conducted one internally. No violations were observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sunnyside Care	***Provider Number***	2754
Address	907 IDA BELLE ST ,	***Approval Status***	Approved
City, State, Zip	Sunnyside, WA 989449062	***Facility Type***	Residential Care

On 08/12/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Julie Santiago Executive Director

Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by Andrea Ely
Date: 2026.08.12 12:51:10 -07'00'
Adobe Acrobat Reader version: 2026.001.21771

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____