Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sunnyside Care	***Provider Number***	2754
Address	907 IDA BELLE ST ,	***Approval Status***	Approved
City, State, Zip	Sunnyside, WA 989449062	***Facility Type***	Residential Care

On 09/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 240669 Here's a complaint of Fire Panel Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	On September 29, 2026, an inspection was completed for complaint #240669 at Sunnyside Care Assisted Living located at 907 Ida Belle Street in Sunnyside, Washington. During that inspection the fire alarm system was noted as being in normal status, stating "All Systems Normal." Staff stated that the fire alarm system was repaired on September 15, 2026 at approximately 0830 hours, which aligns with the service report and fire watch documentation observed on site. There was no fire, no fire and life safety systems activated, no fire department response, and no staff or residents were injured, relocated, or evacuated. No violations noted.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Julie Santiago, Executive Director

Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by Andrea Ely
Date: 2026.09.29 15:38:26 -07'00'
Adobe Acrobat Reader version: 2026.002.21931

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.