Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Reviewed last 2 quarterly reports, 3/12/26 and 5/626 from Patriot Fire.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

3 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. Exceptions: 1. The distance of travel to reach an extinguisher shall not apply The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies. 2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met: 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed. 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal. 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment. 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed. 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10. 3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations. (IFC 906.2 2021)	Completed.

4 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Completed.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

5 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes. (IFC 1031.10.2 2021)	Completed.

6 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Completed and back on track on monthlies.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
7 NFPA 80 Fire Door Inspection and Testing	
5.2.1 Inspection and Testing. Upon completin of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4. 5.2.4 Periodic Inspection and Testing. 5.2.4.1 Periodic inspections and testing shall be performed not less than annually. 5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information: 1. Date of inspection 2. Name of facility 3. Address of facility 4. Name of person(s) performing inspections and testing 5. Company name and address of inspecting company 6. Signature of inspector of record 7. Individual record of each inspected and tested fire door assembly 8. Opening identifier and location of each inspected and tested fire door assembly 9. Type and description of each inspected and tested fire door assembly 10. Verification of visual inspection and functional operation 11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4 And the following hall be checked: 1. Labels are clearly visible and legible 2. No open holes or breaks exist in surfaces of wither the door or frame 3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped. 4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage 5. No parts are missing or broken 6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7 7. The self-closing device is operational,: that is, the active door completely closes when operated from the full open position 8. If a coordinator is installed, the inactive lead close	Corrected.

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
before the active lead 9. Latching hardware operates and secures the door when it is in the closed positon 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been preformed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

8 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	Reports provided.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Olympus Living at Spokane Valley	***Provider Number***	2755
Address	17121 E 8TH AVE ,	***Approval Status***	Approved
City, State, Zip	Spokane Valley, WA 99016	***Facility Type***	Residential Care

On 07/23/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement | Statement of Violation

Next inspection scheduled on or after: 06/30/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Shelby Strider CEO
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.