Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Spokane Memory Care at South Hill	***Provider Number***	2768
Address	4503 S FREYA ST ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99223	***Facility Type***	Residential Care

On 08/27/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."	For your information.

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	In the laundry room west there is a fire alarm control unit booster panel with batteries from 2021. For your information batteries are to be replaced at 5 years.

3 Smoke Detector Sensitivity

Smoke detector sensitivity shall be checked within one year after installation and every alternate year thereafter. After the second calibration test, where sensitivity tests indicate that the detector has remained within its listed and marked sensitivity range (or 4-percent obscuration light grey smoke, if not marked), the length of time between calibration tests shall be permitted to be extended to a maximum of 5 years. Where the frequency is extended, records of detector-caused nuisance alarms and subsequent trends of these alarms shall be maintained. In zones or areas where nuisance alarms show any increase over the previous year, calibration tests shall be performed. (IFC 907.8.3 2021)	The facility has scheduled sensitivity testing scheduled 8/28/26 with their contractor. Please ensure that the report is provided and maintained.

Initials of Authorized Facility Representative: BC

This document was prepared by Residential Care Services for the Locator website.

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Spokane Memory Care at South Hill	***Provider Number***	2768
Address	4503 S FREYA ST ,	***Approval Status***	Approved
City, State, Zip	Spokane, WA 99223	***Facility Type***	Residential Care

On 08/27/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement — Statement of Violation

Next inspection scheduled on or after: 09/30/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

B. Current — *Signature*

Brandon Current Maint. — Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara D. McMullen — *Signature*

Initials of Authorized Facility Representative: BC

This document was prepared by Residential Care Services for the Locator website.