Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Grandview Village Retirement Community	***Provider Number***	000977
Address	5800 64TH ST NE,	***Approval Status***	Approved
City, State, Zip	Marysville, WA 98270	***Facility Type***	Residential Care

On 08/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

1 Admin Complaint

COMPLAINT # 237321 Here's a complaint of Smoke Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 237321 At 1300 on 08/24/2026, DSFM Brown conducted complaint inspection for Grandview Village Retirement Community located at 5800 64th St NE, Marysville, WA 98270 to investigate complaint ref # 237321. I interviewed the Facility Maintenance Director. On 08/19/2026 at 1017 the fire alarm activated. Staff responded to the fire panel that stated “South/East 500”. Staff also reported the smell of smoke in the hallway. Maintenance Director and staff removed residents from all affected rooms in the area to the muster station. Fire Department arrived on scene and used a heat detection device, and no signs of heat were identified. FD silenced alarm and stated all clear at approximately 1041 and residents were returned to their rooms. Out of caution a modified fire watch was initiated to look for any indication of smoke or fire. All apartments are inspected by this Executive Director and Maintenance Director for lighting, electrical appliances and lights that could be at risk. It was discovered that a light bulb in the ceiling near room 506 had a burnt-out bulb causing the smoke. Fans were used to clear the hallways of any residual smoke. No injuries were reported. No sprinkler activation No violations observed.

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____

Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Grandview Village Retirement Community	***Provider Number***	000977
Address	5800 64TH ST NE,	***Approval Status***	Approved
City, State, Zip	Marysville, WA 98270	***Facility Type***	Residential Care

On 08/24/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.

Initials of Authorized Facility Representative: _____