

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016461	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 08/13/2026
NAME OF PROVIDER OR SUPPLIER VICTORY RESOURCES LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 5014 N 19TH PLACE MILWAUKEE, WI 53209		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 08/13/2026. Surveyor completed an abbreviated survey at Victory Resources LLC. One deficiency was identified. Census: 4	M 000		
M 332	88.05(4)(a) FIRE SAFETY-FIRE EXTINGUISHERS Fire extinguishers. Every adult family home shall be equipped with one or more fire extinguishers on each floor. Each required fire extinguisher shall have a minimum 2A, 10-B-C rating. All required fire extinguishers shall be mounted. A fire extinguisher is required at the head of each stairway and in or near the kitchen except that a single fire extinguisher located in close proximity to the kitchen and the head of a stairway may be used to meet the requirement for an extinguisher at each location. Each required fire extinguisher shall be maintained in readily usable condition and shall be inspected annually by the authorized dealer or the local fire department and have an attached tag showing the date of the last dealer or fire department inspection. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure 3 of 3 fire extinguishers were inspected annually by an authorized dealer. The fire extinguishers located in the kitchen, hallway, and basement, were last inspected April 2025.	M 332		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016461	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 08/13/2026
NAME OF PROVIDER OR SUPPLIER VICTORY RESOURCES LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 5014 N 19TH PLACE MILWAUKEE, WI 53209		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
M 332	Continued From page 1 Findings include: On 08/12/2026, at approximately 9:45 AM, Surveyor toured the facility and observed the following: The fire extinguishers, located in the kitchen, hallway, and basement had an inspection tag which identified the fire extinguisher was last inspected in April 2025. On 08/12/2026, at 10:30 AM, Surveyor interviewed Licensee A. Licensee A confirmed the fire extinguishers were to be inspected annually. Licensee A reported s/he was unaware of the fire extinguishers being expired. Licensee A reported s/he would have the fire extinguishers inspected.	M 332			